

Vent pipe must be complete and properly strapped.

Master cut off and flex line needs to be installed. (If appliance is not (connected, either cut off or flex line needs to be c>> BD lugged)ped.