

## Reference 2015 IFGC (International Fuel Gas Code) Amendment Code Chapter 10

No Customer Piping installed – Section 403.10.5

Customer Piping not complete – Section 403.10.5

Open Customer Piping (Customer Piping is open/not capped. Cannot perform pressure test if piping is open) – Section 403.10.5

Customer Piping is in a strain (Piping is in bind or under stress due to improperly sized fittings used or piping cut to improper length) – Section 401.8 & 402

Customer Piping not strapped (Piping not securely fastened to support structure or wall) –